

OVERFLOW REPORT - Springfield Water and Sewer Commission

FEBRUARY 2019

Monthly Rainfall Summary

Monthly Overflow Summary

NPDES Site	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (H.M)
CSO 007	0	0	0.0
CSO 008	0	0	0.0
CSO 010	2	2,370,000	11.8
CSO 011	0	0	0.0
CSO 012	4	4,870,000	47.2
CSO 013	0	0	0.0
CSO 014	2	20,000	1.0
CSO 015A	2	240,000	34.1
CSO 015B	0	0	0.0
CSO 016	2	780,000	20.6
CSO 017	0	0	0.0
CSO 018	0	0	0.0
CSO 019	0	0	0.0
CSO 024	0	0	0.0
CSO 025	0	0	0.0
CSO 034	0	0	0.0
CSO 035	0	0	0.0
CSO 036	0	0	0.0
CSO 037	0	0	0.0
CSO 045	0	0	0.0
CSO 046	0	0	0.0
CSO 048	0	0	0.0
CSO 049	0	0	0.0
Total	12	8,280,000	114.7

Site	Total Rain (in.)
RG01	2.94
RG02	2.93
RG03	3.17
RG04	3.38
Bondi's	2.87

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather

