

OVERFLOW REPORT - Springfield Water and Sewer Commission

January 2020

Monthly Overflow Summary

NPDES Site	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (H.M)
CSO 007	0	0	0.0
CSO 008	1	29,000	0.3
CSO 010	1	1,649,000	3.2
CSO 011	0	0	0.0
CSO 012	3	704,000	5.5
CSO 013	1	385,000	2.5
CSO 014	1	443,000	2.4
CSO 015A	3	133,000	11.5
CSO 015B	0	0	0.0
CSO 016	1	1,190,000	3.5
CSO 017	1	1,000	0.5
CSO 018	1	13,000	1.2
CSO 019	0	0	0.0
CSO 024	0	0	0.0
CSO 025	1	15,000	0.2
CSO 034	1	1,000	0.5
CSO 035	0	0	0.0
CSO 036	0	0	0.0
CSO 037	0	0	0.0
CSO 045	1	3,000	0.2
CSO 046	1	5,000	0.2
CSO 048	0	0	0.0
CSO 049	3	185,000	6.7
Total	20	4,756,000	38.2

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01*	1.13
RG02	1.39
RG03	1.78
RG04	1.67
Courtside-RG	1.82
DPW-RG	1.54
Fire-RG	1.67
Glenmore-RG	1.51
RyanCir-RG	2.00
SWSC-RG	1.20
Washburn-RG	1.95
York-RG*	1.15

*RG clogged

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather