

OVERFLOW REPORT - Springfield Water and Sewer Commission

July 2019

Monthly Overflow Summary

NPDES Site	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (H.M)
CSO 007	0	0	0.0
CSO 008	1	325,000	13.0
CSO 010	3	10,830,000	22.0
CSO 011	1	13,097	0.2
CSO 012	4	4,354,000	20.7
CSO 013	3	1,893,000	8.0
CSO 014	3	1,986,000	10.8
CSO 015A	4	2,762,000	0.0
CSO 015B	3	396,000	1.5
CSO 016	4	6,750,000	11.1
CSO 017	1	12,000	0.5
CSO 018	0	0	0.0
CSO 019	0	0	0.0
CSO 024	0	0	0.0
CSO 025	0	0	0.0
CSO 034	1	30,000	11.8
CSO 035	4	254,000	0.0
CSO 036	2	802,000	0.8
CSO 037	3	80,000	1.3
CSO 045	0	0	0.0
CSO 046	3	1,105,000	1.8
CSO 048	1	1,000	0.1
CSO 049	4	412,000	9.5
Total	45	32,005,097	112.9

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	4.74
RG02	4.46
RG03	6.24
RG04	5.07
Bondi's	6.00

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather