

OVERFLOW REPORT - Springfield Water and Sewer Commission

June 2019

Monthly Overflow Summary

NPDES Site	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (H.M)
CSO 007	0	0	0.0
CSO 008	1	1,075,000	0.0
CSO 010	3	689,000	4.5
CSO 011	0	0	0.0
CSO 012	5	1,659,163	18.6
CSO 013	0	0	0.0
CSO 014	1	19,075	0.3
CSO 015A	6	176,361	23.6
CSO 015B	0	0	0.0
CSO 016	2	1,028,000	6.1
CSO 017	0	0	0.0
CSO 018	0	0	0.0
CSO 019	0	0	0.0
CSO 024	0	0	0.0
CSO 025	0	0	0.0
CSO 034	0	0	0.0
CSO 035	1	5,711	0.1
CSO 036	0	0	0.0
CSO 037	0	0	0.0
CSO 045	1	0	0.0
CSO 046	0	0	0.0
CSO 048	0	0	0.0
CSO 049	1	14,000	0.2
Total	21	4,666,310	53.3

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	2.24
RG02	1.73
RG03	1.87
RG04	2.32
Bondi's	1.69

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather: