

OVERFLOW REPORT - Springfield Water and Sewer Commission

June 2020

Monthly Overflow Summary

NPDES Site	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (H.M)
CSO 007	0	0	0.0
CSO 008	0	0	0.0
CSO 010	1	722,000	3.3
CSO 011	0	0	0.0
CSO 012	2	867,000	19.3
CSO 013	1	154,000	0.8
CSO 014	2	112,000	18.5
CSO 015A	2	150,000	12.6
CSO 015B	0	0	0.0
CSO 016	1	94,000	0.5
CSO 017	0	0	0.0
CSO 018	0	0	0.0
CSO 019	1	252,829	0.2
CSO 024	0	0	0.0
CSO 025	3	7,000	1.5
CSO 034	1	75,000	3.4
CSO 035	1	167,000	0.7
CSO 036	1	157,000	18.6
CSO 037	1	2,000	0.3
CSO 045	0	0	0.0
CSO 046	1	5,000	0.3
CSO 048	1	39,000	0.4
CSO 049	1	21,000	0.4
Total	20	2,824,829	80.5

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	1.91
RG02	1.60
RG03	1.43
RG04	3.27
Courtside-RG	2.23
DPW-RG	1.75
Fire-RG	2.08
Glenmore-RG	2.87
RyanCir-RG	2.13
SWSC-RG	1.67
Washburn-RG	1.92
York-RG	1.68

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather: