

# OVERFLOW REPORT - Springfield Water and Sewer Commission

March 2019

## Monthly Overflow Summary

NPDES Site - See individual sheets for daily activity	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (H.M)
CSO 007	0	0	0.0
CSO 008	0	0	13.0
CSO 010	2	357,085	3.1
CSO 011	0	0	0.0
CSO 012	6	3,138,000	42.6
CSO 013	0	0	0.0
CSO 014	1	8,114	0.0
CSO 015A	5	316,000	44.0
CSO 015B	0	0	0.0
CSO 016	4	2,597,000	12.8
CSO 017	1	5,319	0.2
CSO 018	1	36,000	0.3
CSO 019	0	0	0.0
CSO 024	0	0	0.0
CSO 025	1	6,334	0.3
CSO 034	0	0	0.0
CSO 035	0	0	0.0
CSO 036	0	0	0.0
CSO 037	0	0	0.0
CSO 045	0	0	0.0
CSO 046	1	17,637	1.8
CSO 048	0	0	0.0
CSO 049	0	0	0.0
<b>Total</b>	<b>22</b>	<b>6,481,490</b>	<b>117.9</b>

## Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	2.32
RG02	2.80
RG03	3.41
RG04	2.56
Bondi's	1.58

\*\* Meter Downtime due to access restrictions leading to a dead battery

\*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather