

**OVERFLOW REPORT - Springfield Water and Sewer Commission**

**March 2020**

**Monthly Overflow Summary**

NPDES Site - See individual sheets for daily activity	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (H.M)
CSO 007	0	0	0.0
CSO 008	0	0	0.0
CSO 010	4	3,375,000	14.2
CSO 011	0	0	0.0
CSO 012	4	2,816,000	22.6
CSO 013	2	344,000	8.0
CSO 014	2	958,000	5.3
CSO 015A	4	292,000	14.3
CSO 015B	0	0	0.0
CSO 016	4	5,390,000	20.3
CSO 017	0	0	0.0
CSO 018	0	0	0.0
CSO 019	0	0	0.0
CSO 024	0	0	0.0
CSO 025	1	8,000	1.5
CSO 034	1	1,000	1.3
CSO 035	0	0	0.0
CSO 036	0	0	0.0
CSO 037	0	0	0.0
CSO 045	0	0	0.0
CSO 046	1	2,000	0.4
CSO 048	0	0	0.0
CSO 049	0	0	0.0
<b>Total</b>	<b>23</b>	<b>13,186,000</b>	<b>87.9</b>

**Monthly Rainfall Summary**

Site	Total Rain (in.)
RG01	4.26
RG02	3.65
RG03	4.47
RG04	4.02
Courtside-RG	4.11
DPW-RG	3.89
Fire-RG	4.28
Glenmore-RG	3.80
RyanCir-RG	4.51
SWSC-RG	3.37
Washburn-RG	4.24
York-RG	4.20

\*RG clogged

\*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather