

# OVERFLOW REPORT - Springfield Water and Sewer Commission

May 2020

Monthly Overflow Summary

NPDES Site	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (H.M)
CSO 007	0	0	0.0
CSO 008	0	0	0.0
CSO 010	2	3,744,000	20.0
CSO 011	0	0	0.0
CSO 012	3	1,680,000	23.8
CSO 013	1	538,000	1.3
CSO 014	3	1,213,000	0.0
CSO 015A	3	244,000	6.8
CSO 015B	0	0	0.0
CSO 016	3	5,305,000	19.6
CSO 017	1	16,000	0.3
CSO 018	1	1,000	0.5
CSO 019	0	0	0.0
CSO 024	0	0	0.0
CSO 025	2	27,000	16.3
CSO 034	1	43,000	0.5
CSO 035	1	39,000	0.2
CSO 036	1	65,000	0.2
CSO 037	1	9,000	0.3
CSO 045	2	18,000	16.0
CSO 046	2	83,000	16.6
CSO 048	1	36,000	0.5
CSO 049	2	84,000	16.5
<b>Total</b>	<b>30</b>	<b>13,145,000</b>	<b>139.3</b>

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	2.28
RG02	2.24
RG03	2.30
RG04	2.59
Courtside-RG	2.25
DPW-RG	2.30
Fire-RG	2.37
Glenmore-RG	1.97
RyanCir-RG	2.75
SWSC-RG	1.93
Washburn-RG	2.31
York-RG*	1.40

\*meter downtime - needs manual collect or swap

\*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather