

OVERFLOW REPORT - Springfield Water and Sewer Commission

December

2022

NPDES Site	Watershed Discharge	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (Hours)
CSO 007	Connecticut River	0	0	0.0
CSO 008	Connecticut River	0	0	0.0
CSO 010	Connecticut River	4	7,463,000	28.3
CSO 011	Connecticut River	0	0	0.0
CSO 012	Connecticut River	4	5,658,000	17.0
CSO 013	Connecticut River	0	0	0.0
CSO 014	Connecticut River	3	1,641,000	18.3
CSO 015A	Connecticut River	0	0	0.0
CSO 015B	Connecticut River	0	0	0.0
CSO 016	Connecticut River	3	7,662,000	9.3
CSO 017	Mill River	0	0	0.0
CSO 018	Connecticut River	0	0	0.0
CSO 019	Mill River	0	0	0.0
CSO 024	Mill River	0	0	0.0
CSO 025	Mill River	0	0	0.0
CSO 034	Chicopee River	0	0	0.0
CSO 035	Chicopee River	0	0	0.0
CSO 036A	Chicopee River	0	0	0.0
CSO 037	Chicopee River	0	0	0.0
CSO 042	Connecticut River	0	0	0.0
CSO 045	Mill River	0	0	0.0
CSO 046	Mill River	0	0	0.0
CSO 048	Mill River	0	0	0.0
CSO 049	Connecticut River	5	408,000	17.3
Total		19	22,832,000	90.2

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	4.71
RG02	3.62
RG03	3.94
RG04	4.20
Courtside-RG	4.60
DPW-RG	4.08
Fire-RG	4.07
Glenmore-RG	3.76
RyanCir-RG	4.02
SWSC-RG	3.45
Washburn-RG	4.69
York-RG	4.08

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather