

OVERFLOW REPORT - Springfield Water and Sewer Commission

January

2023

NPDES Site	Watershed Discharge	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (Hours)
CSO 007	Connecticut River	0	0	0.0
CSO 008	Connecticut River	1	927,000	1.8
CSO 010	Connecticut River	6	14,574,000	40.0
CSO 011	Connecticut River	0	0	0.0
CSO 012	Connecticut River	5	4,183,000	24.9
CSO 013	Connecticut River	2	2,248,000	3.7
CSO 014	Connecticut River	6	3,397,000	27.2
CSO 015A	Connecticut River	0	0	0.0
CSO 015B	Connecticut River	1	23,000	1.3
CSO 016	Connecticut River	6	6,959,000	13.9
CSO 017	Mill River	0	0	0.0
CSO 018	Connecticut River	0	0	0.0
CSO 019	Mill River	0	0	0.0
CSO 024	Mill River	0	0	0.0
CSO 025	Mill River	0	0	0.0
CSO 034	Chicopee River	0	0	0.0
CSO 035	Chicopee River	0	0	0.0
CSO 036A	Chicopee River	0	0	0.0
CSO 037	Chicopee River	0	0	0.0
CSO 042	Connecticut River	2	2,892,000	3.8
CSO 045	Mill River	0	0	0.0
CSO 046	Mill River	2	65,000	3.4
CSO 048	Mill River	0	0	0.0
CSO 049	Connecticut River	6	1,159,000	48.1
Total		37	36,427,000	168.2

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	6.63
RG02	5.56
RG03	6.32
RG04	6.04
Courtside-RG	6.81
DPW-RG	6.45
Fire-RG	6.67
Glenmore-RG	6.30
RyanCir-RG	5.79
SWSC-RG	5.18
Washburn-RG	6.66
York-RG	6.16

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather