

OVERFLOW REPORT - Springfield Water and Sewer Commission

February

2023

NPDES Site	Watershed Discharge	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (Hours)
CSO 007	Connecticut River	0	0	0.0
CSO 008	Connecticut River	0	0	0.0
CSO 010	Connecticut River	2	339,000	3.5
CSO 011	Connecticut River	0	0	0.0
CSO 012	Connecticut River	2	212,000	1.3
CSO 013	Connecticut River	0	0	0.0
CSO 014	Connecticut River	1	31,000	0.5
CSO 015A	Connecticut River	0	0	0.0
CSO 015B	Connecticut River	0	0	0.0
CSO 016	Connecticut River	2	569,000	3.2
CSO 017	Mill River	0	0	0.0
CSO 018	Connecticut River	0	0	0.0
CSO 019	Mill River	0	0	0.0
CSO 024	Mill River	0	0	0.0
CSO 025	Mill River	0	0	0.0
CSO 034	Chicopee River	0	0	0.0
CSO 035	Chicopee River	0	0	0.0
CSO 036	Chicopee River	0	0	0.0
CSO 037	Chicopee River	0	0	0.0
CSO 042	Connecticut River	0	0	0.0
CSO 045	Mill River	0	0	0.0
CSO 046	Mill River	0	0	0.0
CSO 048	Mill River	0	0	0.0
CSO 049	Connecticut River	2	77,000	2.5
Total		9	1,228,000	11.0

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	1.66
RG02	1.45
RG03	1.60
RG04	1.94
Courtside-RG	1.35
DPW-RG	1.70
Fire-RG	1.83
Glenmore-RG	1.36
RyanCir-RG	1.39
SWSC-RG	1.36
Washburn-RG	1.85
York-RG	1.80

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather