

OVERFLOW REPORT - Springfield Water and Sewer Commission

March

2023

NPDES Site	Watershed Discharge	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (Hours)
CSO 007	Connecticut River	0	0	0.0
CSO 008	Connecticut River	0	0	0.0
CSO 010	Connecticut River	4	5,727,000	24.4
CSO 011	Connecticut River	0	0	0.0
CSO 012	Connecticut River	1	2,144,000	15.2
CSO 013	Connecticut River	0	0	0.0
CSO 014	Connecticut River	1	524,000	13.8
CSO 015A	Connecticut River	0	0	0.0
CSO 015B	Connecticut River	0	0	0.0
CSO 016	Connecticut River	1	993,000	4.2
CSO 017	Mill River	0	0	0.0
CSO 018	Connecticut River	0	0	0.0
CSO 019	Mill River	0	0	0.0
CSO 024	Mill River	0	0	0.0
CSO 025	Mill River	0	0	0.0
CSO 034	Chicopee River	0	0	0.0
CSO 035	Chicopee River	0	0	0.0
CSO 036A	Chicopee River	0	0	0.0
CSO 037	Chicopee River	0	0	0.0
CSO 042	Connecticut River	0	0	0.0
CSO 045	Mill River	0	0	0.0
CSO 046	Mill River	0	0	0.0
CSO 048	Mill River	0	0	0.0
CSO 049	Connecticut River	1	24,000	1.1
Total		8	9,412,000	58.6

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	5.12
RG02	4.34
RG03	4.52
RG04	4.26
Courtside-RG	5.19
DPW-RG	4.78
Fire-RG	5.07
Glenmore-RG	4.94
RyanCir-RG	3.34
SWSC-RG	3.07
Washburn-RG	5.84
York-RG	4.89

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather