

OVERFLOW REPORT - Springfield Water and Sewer Commission
March 2026

NPDES Site	Watershed Discharge	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (Hours)
CSO 007	Connecticut River	0	0	0.0
CSO 008	Connecticut River	0	0	0.0
CSO 010	Connecticut River	4	2,844,000	11.2
CSO 011	Connecticut River	0	0	0.0
CSO 012	Connecticut River	4	3,002,000	12.9
CSO 013	Connecticut River	0	0	0.0
CSO 014	Connecticut River	4	334,000	4.9
CSO 015A	Connecticut River	0	0	0.0
CSO 015B	Connecticut River	0	0	0.0
CSO 016	Connecticut River	0	0	0.0
CSO 017	Mill River	0	0	0.0
CSO 018	Connecticut River	0	0	0.0
CSO 019	Mill River	0	0	0.0
CSO 024	Mill River	0	0	0.0
CSO 025	Mill River	0	0	0.0
CSO 034	Chicopee River	0	0	0.0
CSO 035	Chicopee River	0	0	0.0
CSO 036A	Chicopee River	0	0	0.0
CSO 037	Chicopee River	0	0	0.0
CSO 042	Connecticut River	4	10,988,792	5.7
CSO 045	Mill River	0	0	0.0
CSO 046	Mill River	1	2,000	0.6
CSO 048	Mill River	0	0	0.0
CSO 049	Connecticut River	1	4,000	0.2
Total		18	17,174,792	35.5

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	4.72
RG02	4.14
RG03*	3.84**
RG04	3.78
Courtside-RG	4.72
DPW-RG	4.80
Fire-RG	3.04
Glenmore-RG	4.10
RyanCir-RG*	4.34
SWSC-RG	4.13
Washburn-RG	3.46**
York-RG	4.51

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather