

OVERFLOW REPORT - Springfield Water and Sewer Commission
April 2026

NPDES Site	Watershed Discharge	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (Hours)
CSO 007	Connecticut River	0	0	0.0
CSO 008	Connecticut River	0	0	0.0
CSO 010	Connecticut River	1	1,698,000	3.7
CSO 011	Connecticut River	0	0	0.0
CSO 012	Connecticut River	3	1,517,000	4.7
CSO 013	Connecticut River	1	388,000	0.6
CSO 014	Connecticut River	1	348,000	2.7
CSO 015A	Connecticut River	0	0	0.0
CSO 015B	Connecticut River	1	2,000	0.2
CSO 016	Connecticut River	1	2,555,000	2.9
CSO 017	Mill River	1	17,000	0.2
CSO 018	Connecticut River	1	19,000	0.2
CSO 019	Mill River	0	0	0.0
CSO 024	Mill River	0	0	0.0
CSO 025	Mill River	1	39,000	0.2
CSO 034	Chicopee River	2	34,000	0.8
CSO 035	Chicopee River	0	0	0.0
CSO 036A	Chicopee River	2	21,000	0.2
CSO 037	Chicopee River	0	0	0.0
CSO 042	Connecticut River	1	1,663,818	0.7
CSO 045	Mill River	1	343,000	0.6
CSO 046	Mill River	1	16,000	0.4
CSO 048	Mill River	1	34,000	0.4
CSO 049	Connecticut River	1	34,000	0.3
Total		20	8,728,818	19.1

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	2.80
RG02	2.69
RG03**	2.52
RG04***	1.90
Courtside-RG	2.59
DPW-RG	0.44
Fire-RG	2.21
Glenmore-RG	2.82
RyanCir-RG*	1.69
SWSC-RG	2.32
Washburn-RG	2.61
York-RG	2.61

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather