

OVERFLOW REPORT - Springfield Water and Sewer Commission
June 2026

NPDES Site	Watershed Discharge	# of Overflow Events (24 Hr. Response)*	Total Overflow Volume (Gal)	Overflow Duration (Hours)
CSO 007	Connecticut River	0	0	0.0
CSO 008	Connecticut River	0	0	0.0
CSO 010	Connecticut River	3	2,262,000	5.7
CSO 011	Connecticut River	0	0	0.0
CSO 012	Connecticut River	6	1,035,000	5.6
CSO 013	Connecticut River	2	1,033,000	0.9
CSO 014	Connecticut River	5	253,000	3.5
CSO 015A	Connecticut River	2	1,991,000	0.4
CSO 015B	Connecticut River	0	0	0.0
CSO 016	Connecticut River	N/A	N/A	N/A
CSO 017	Mill River	0	0	0.0
CSO 018	Connecticut River	0	0	0.0
CSO 019	Mill River	0	0	0.0
CSO 024	Mill River	0	0	0.0
CSO 025	Mill River	3	44,000	0.4
CSO 034	Chicopee River	1	1,000	0.1
CSO 035	Chicopee River	0	0	0.0
CSO 036A	Chicopee River	0	0	0.0
CSO 037	Chicopee River	0	0	0.0
CSO 042	Connecticut River	5	2,487,014	1.2
CSO 045	Mill River	0	0	0.0
CSO 046	Mill River	1	1,000	0.2
CSO 048	Mill River	2	180,000	1.0
CSO 049	Connecticut River	4	149,000	1.2
Total		34	9,436,014	20.2

Monthly Rainfall Summary

Site	Total Rain (in.)
RG01	2.52
RG02	1.87
RG03*	2.66
RG04	2.14
Courtside-RG	2.05
DPW-RG	2.61
Fire-RG	2.52
Glenmore-RG	2.09
RyanCir-RG*	1.79
SWSC-RG	2.21
Washburn-RG	2.30
York-RG	1.90

*A storm event is any period of precipitation which is preceded and followed by 24 hours of dry weather